




Resolution – Authorization to use Eminent Domain – T531 Hunter-Purgatory Transmission Line Upgrade

Jonathan Greene | Chief Operations Officer - Transmission

T531 Hunter-Purgatory TL Upgrade

- Project is needed to increase capacity to serve growing load and to ensure reliable operation of PEC's system
- Easement costs approved in 2025 Capital Improvement Plan
- Remaining costs for the project are part of 2027 Capital Improvement Plan
 - Remove wood poles on existing 8.3-mile transmission line and rebuild with steel monopole structures, single Suwannee conductor, and OPGW
- Easement amendments will be required for the upgrade project
- PEC will deliver initial offers to affected landowners. In the event we are unable to acquire the easement interests through negotiation and purchase, PEC will see to acquire the easements through its power of eminent domain.
- Requesting approval for the use of eminent domain, if necessary, to amend easement rights.





myPEC.com